


### PROBLEM 4.24

**KNOWN:** Operating conditions of a buried superconducting cable.

**FIND:** Required cooling load.

**SCHEMATIC:**



**ASSUMPTIONS:** (1) Steady-state conditions, (2) Constant properties, (3) Two-dimensional conduction in soil, (4) One-dimensional conduction in insulation, (5) Pipe inner surface is at liquid nitrogen temperature.

**ANALYSIS:** The heat rate per unit length is

$$q' = \frac{T_g - T_n}{R'_g + R'_I}$$

$$q' = \frac{T_g - T_n}{\left[ k_g \left( 2\pi / \ln(4z/D_o) \right) \right]^{-1} + \ln(D_o / D_i) / 2\pi k_i}$$

where Tables 3.3 and 4.1 have been used to evaluate the insulation and ground resistances, respectively. Hence,

$$q' = \frac{(300 - 77) \text{ K}}{\left[ (1.2 \text{ W/m} \cdot \text{K}) \left( 2\pi / \ln(8/0.2) \right) \right]^{-1} + \ln(2) / 2\pi \times 0.005 \text{ W/m} \cdot \text{K}}$$

$$q' = \frac{223 \text{ K}}{(0.489 + 22.064) \text{ m} \cdot \text{K/W}}$$

$$q' = 9.9 \text{ W/m.} \quad <$$

**COMMENTS:** The heat gain is small and the dominant contribution to the thermal resistance is made by the insulation.